

## Identification of Multi-Machine Power System Coherent Group in Nigeria

Okhueigbe E.I.<sup>1</sup>, Okhueigbe A.O.<sup>2</sup>, Oshevire P.O.<sup>3</sup>

1 Oskas-Jo & Partners LTD, Edo State, Nigeria.

2 NMR Intercontinental Limited, Ikeja Lagos State, Nigeria.

3 FOPRE, Delta State.

\*Corresponding author: Okhueigbe E.I

Oskas-Jo & Partners LTD,

Edo State, Nigeria.

E-mail: [ighomma4real@yahoo.com](mailto:ighomma4real@yahoo.com)

Received: April 19, 2014, Accepted: May 15, 2014, Published: May 16, 2014.

### ABSTRACT

This paper discusses Nigeria 330KV integrated power system coherent groups of generators for coherency based analysis method for network reduction to carry out transient stability analysis for multi-machine power system network. This method is based on the following different indices, the first one is inertia condition index and second one is initial power variation index. The coherency identification method has the ability to identify perfect coherent groups in a very simple way, so that the nature of the machines in the reduced order system is exactly similar to those of the full system. Each coherent group is replaced by a single machine using the method of dynamic equivalent construction. The proposed test system involves the integrated network consisting of 39 buses.

**Keyword:** generators, buses, dynamic equivalents, inertia constant, initial power variation, Nigeria.

### INTRODUCTION

Increasing interconnection of power plants in modern large electric power systems has made power system dynamic studies much more complex. Under the deregulated business environment, the interconnections are increasingly being used for trading between utilities. Modern power systems are so large; power system analysis programs do not usually model the complete system in detail. [3]. This problem of modeling a large system arises for a number of reasons including: Practical limitations on the size of computer memory, the excessive computing time required by large power systems; particularly when running dynamic simulation and stability programs, parts of the system far away from a disturbance have little effect on the system dynamics and it is therefore unnecessary to model them in details. The computational time can be reduced if the transient stability is determined in a reduced order equivalent model of the original system. Coherency-based approaches to dynamic equivalents have been adopted in reducing the size of the power system model [4], [6] and [16]. For system reduction, coherency based method for transient stability study being most popular because the coherent generator technique is an elegant and powerful tool through construction of simplified reduced order dynamic models which can represent the entire system without loss of system significant characteristics [14]. The reduction is based on the impact of large disturbances in a particular area known as the study system, while system external to study area are not of direct interest in stability analysis; and are thus represented by dynamic equivalents in recognition of its influence on the

response of the study area to disturbances. To find out coherent generators, a large multi-machine system is divided into a study sub-system and an external sub-system depending on power variation of the generators at the instant of initiated fault [2] and [16]. The internal sub-system includes the disturbance and a small number of generators of great concern. These generators are severely disturbed and are in general responsible for the system instability. The rest of generators are considered in the external system. The generators in the external system do not contribute significantly to the system instability. Thus the dynamic equivalence technique is applied on these generators only. Power system division is based on the generators close to fault have a tendency to accelerate much faster than the generators away from the disturbance [7]. For power system coherent group this paper presents a new simple method based on two different indices, the first one is inertia condition index and second one is initial power variation index. The proposed method has been applied on; 39-bus in Nigeria test power system in two separate fault locations and a satisfactory result has been obtained.

### PROPOSED POWER SYSTEM COHERENT GROUP IDENTIFICATION METHOD

Coherency is defined by the property that following any disturbance of the difference of rotor angles of the coherent machines remains constant in time [10] and [9], i.e:  $\delta_i t - \delta_j t = \text{constant} = \delta_{ij}^0$  (1) Where,  $\delta_{ij}^0 = (\delta_i^0 - \delta_j^0)$  is the difference of the pre-fault values.

**Inertia Condition Index** Inertia Constant is a basic parameter of the machines. This constant can help to find out the coherent groups. This index is based on normalized value of inertia differences among the machines. Inertia Condition index  $\beta_{ij}$  is defined by the expression  $\beta_{ij} = |M_i - M_j| / \text{Max}(M_{i,j}) = \beta_{ij} \leq 0.2$  (2) for  $i=2, 3, 4, \dots, n$ ;  $j=1, 2, 3, \dots, (i-1)$ .

$M_i - M_j =$  Inertia difference between machine no  $i$  &  $j$ . For perfect coherency,  $\beta_{ij}$  must be identically equal to zero. This condition rarely satisfied in practical systems. If one of the inertias tends to infinity  $\beta_{ij}$  will tend to 1 indicating generators deviating from each other [11]. However, in practice  $\beta_{ij} \leq 0.2$  is considered to be satisfactory to conclude that the machines are coherent.

**Initial Power Variation Index** The nature of rotor angle variation of a machine is depended on its power variation. By using this power variation of machines at initial condition, a new coherency index, named initial power variation index may be evaluated. This index may be used further in coherency group identification test. Power variation among the machines at initial condition can give a clear conception of coherency for a particular load arrangement. This index is based on normalized value of power variation among the machines at initial condition. It is defined as:  $IP(ij) = \frac{P_{ei} - P_{ej}}{\text{Max}(P_{ei}, P_{ej})}$  (3) Where,  $i=2, 3, 4, \dots, n$  &  $j=1, 2, 3, \dots, (i-1)$ ;  $n=$  Total number of machines. Here, (Real Power) For initial condition,  $P(i) = E_i \cdot I_i$ ;  $i=1, 2, 3, \dots, n$ ; And,  $E_i = V_i + X_{di}' I_i$  Where,  $V_i =$  Terminal voltage of  $i$ th machine and  $X_{di}' =$  Transient reactance.

**Procedure for Identification of Multi-Machine Power System Coherency.** step-1; Machines are classified into study and external areas depending upon their power variation at the instant of initiating fault. The machines with power variation less than 30% are grouped together as external area machines. The external area machines are considered for coherency grouping test. Step-2; Choosing a reference machine in the external area, all other machines in that area which satisfy Equation (2) are grouped together. Step-3; The initial power variation index,  $IPV_{ij}$  is evaluated for the machines carried over from step-2. If the inequality  $IPV_{ij} \leq 0.03$  is satisfied then the machines will form a coherent group.

## MODEL FOR POWER SYSTEM DYNAMIC EQUIVALENT

The concept of dynamic equivalent in this text is based on Kimbark's method. Also the property of power invariance [12] and [9] is included. This states that whenever number of machines in a coherent group is replaced by a single machine then total power delivered from the group of machines should be equal to the power delivered by the single machine.

### Mathematical Formulation

Formulas for construction of dynamic equivalents are given below [9]:

$$E_e = (m \cdot I_e \cdot I_i / I_e) \cdot (4)$$

Where,  $I_e =$  vector sum of currents of the coherent group.  $m \cdot I_e =$  The voltage of the equivalent machine. And  $m$  is the number of machines in the coherent group. The inertia constant ( $H_e$ ), damping coefficient and mechanical power of the equivalent machine are obtained respectively as.  $H_e = H_i \cdot m$  (5)  $D_e = D_i \cdot m$  (6)  $P_{me} = P_{mi} \cdot m$  (7) The modified transient reactance's are:  $X_{dei}' = [(E_e - V_i) / (E_i - V_i)] \cdot d_i'$  (8) Where,  $X_{dei}'$  is the transient reactance connecting the equivalent machine to the  $i$ th terminal bus [15].

## RESULTS AND DISCUSSION

The proposed coherency identification method has been applied to a multi-machine power system. More over construction of dynamic equivalents were done for the system. Two separate studies were under taken, at first A 3-phase to ground fault was assumed to occur at bus-29 (point A) and secondly another fault was assumed to occur at bus-11 & 35 (point B) and both the faults were cleared automatically at 0.1 sec. For first case, power variation of generator 9 was more than 30% at the instant of initiating fault, so it was in study area and rest of the generators were in external area. For both cases generator 10 was assumed as a reference. By using equation 2 and 3,  $\beta$  and IPV indices were evaluated. After satisfying the conditions of  $\beta$  and IPV indices, Coherent groups: Group I (gen 2, 3, 4, 6 & 7); was found. For second case, generator 2 and 3 were in study area. And, Coherent groups: Group I (gen 4, 6 & 7); was found. After solving the swing equations [8] and [5], swing curves for both full and equivalent systems are given below: 9 8 1 1 8 25 26 28 29 9 10 31 30 18 17 32 33 6 14 15 16 24 21 6 22 7 7 23 4 5 19 4 20 5 3 2 34 35 2 11 36 37 38 10 12 13 39 3 A B  
For fault location at point A.

## CONCLUSION

This paper presents a new simple and an accurate method of identifying the coherent groups of generators. It is necessary to preserve the general behavioral characteristics of the system whenever system is reduced, which can be achieved by using this proposed coherency identification method. This method is based on two different simple indices, the first one is inertia condition index and second one is initial power variation index. The method has been applied to, 39-Bus Nigeria test power system for two different fault locations and the results are found more accurate and satisfactory.

## REFERENCES

1. KRISHAPARANDHAMA, S. ELANGORAN and K. Kuppurajulu, "Method for Identifying Coherent Generators", Vol. 3, No. 2, PP. 85-90, April 1981
2. LEE, S.T.Y., and SCHWEPPE, F.C., "Distance Measure and Coherency Recognition for Transient Stability equivalents", *IEEE Trans.*, 1973, PAS-92, PP. 1550-1557.
3. R. JAMES, W. JANUSZ and JARR MACH, *Power System Dynamics and Stability*, JOHN WILEY and SONS LTD., 1997.
4. G. Troullinos and J. Dorsey, "Coherency and model reduction: State space point of view", *IEEE Trans. Power Syst.*, vol. 4, no. 3, pp. 988-995, Aug. 1989.
5. Website, <http://www.mathworks.com>
6. F. F. Wu and N. N. Murlhi, "Coherency identification for power system dynamic equivalents", *IEEE Trans. Circuits Syst.*, vol. CAS-30, no. 3, pp. 140-147, Mar. 1983.
7. MIR MUJAHID ALI, "Identification of Coherent Generators Using Linear Trajectory", Msc. D. Thesis, University of Ng Fahd of Petroleum and Minerals, Dhahran, Saudi Arabia, 1993.
8. I.J. Nagrath, and D.P. Kothari, *Modern Power System Analysis* (3rd Edition, New Delhi, Tata McGraw-Hill Publishing Company Limited, 2003).
9. M. Y. Hussian and V.G Rau, "A New and Simple Method of Identifying Coherent Generators for Large Power System", *9th*

*International Conference on Electric Power Supply Industries, Hongkong, 1992, Vol.4, pp.193-202.*

10. V. G. Rau and M. Y. Hussian, *Coherent Generators* (Allied Publishers Limited, New Delhi, 1998).
11. M. Y. Hussian and V. G. Rau, "Coherency Identification and Construction of Dynamic Equivalent for large Power System", *Proceedings of 2nd Inter. Confr. on Advances in Power Sys. Control, Operation and Management*, Hongkong, Dec, (1993).
12. E. W. Kimbark, *Power System Stability, vol.1: Synchronous Machine*, John Wiley & Sons (1948).
13. W.D. Stevenson, *Elements of Power System Analysis* (3rd Edition, McGrawHill, 1975).
14. F. I. Izuegbunam, E. C Okafor., S. O. E. Ogbogu, "Coherent

generator based Transient Stability Analysis of the 16 machines, 330KV Nigeria Power System", *Scholarlink Research Institute Journals*, 2011.

15. International Journal of Engineering Research and Development e-ISSN: 2278-067X, p-ISSN: 2278-800X, www.ijerd.com Volume 3, Issue 10 (September 2012), PP. 102-107 102.
16. (Huynh Chau Duy, Huynh Quang Minh, Ho Dac Loc (2012). Transient Stability Analysis of a Multi machine Power System, Faculty of Electrical and Electronics Engineering, HoChiMinh City University of Technology, VietNam.

**Citation:** Okhueigbe E.I, et al (2014) Identification of Multi-Machine Power System Coherent Group in Nigeria. J. of Advancement in Engineering and Technology. VII3. DOI: 10.15297/JAET.VII3.02

**Copyright:** © 2014 Okhueigbe E.I. This is an open-access article distributed under the terms of the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original author and source are credited.